

Reference Home Characteristics

FSEC
111 Anywhere Lane
Colorado Springs, CO,
Registration #:

Title: TaxCredit-AutoGen_case4
TaxRef13

TMY City: CO_COLORADO_SP
Elec Util: Colorado Average
Gas Util: Colorado Average
Run Date:

HERS BESTEST insulated basement case

Above-grade Walls (Uo)	0.060
Above-grade Wall Solar Absorptance	0.75
Above-grade Wall Infrared Emittance	0.90
Basement Walls (Uo)	0.059
Above-grade Floors (Uo)	n/a
Slab Insulation R-Value	0
Ceilings (Uo)	0.030
Roof Solar Absorptance	0.75
Roof Infrared Emittance	0.90
Attic Vent Area (ft²)	5.13
Crawlspace Vent Area (ft²)	n/a
Exposed Masonry Floor Area (ft²)	307.8
Carpet & Pad R-Value	2.0
Door Area (ft²)	40
Door U-Factor	0.35
North Window Area (ft²)	67.50
South Window Area (ft²)	67.50
East Window Area (ft²)	67.50
West Window Area (ft²)	67.50
Window U-Factor	0.35
Window SHGC (Heating)	0.3400
Window SHGC (Cooling)	0.280
SLA (ft²/ft²)	0.00036
Internal Gains Sensible (Btu/day)	83115.7
Internal Gains latent (Btu/day)	17936.9
Internal Gains Total (Btu/day)	101052.6
Labeled Heating System Rating and Efficiency	AFUE = 78%
Labeled Cooling System Rating and Efficiency	SEER = 13.0
Air Distribution System Efficiency	0.80
Gallons per day	60.91
fmix	0.709
Thermostat Type	Manual
Heating Thermostat Settings	68.0, 68.0, 68.0, 68.0, 68.0, 68.0, 68.0, 68.0 68.0, 68.0, 68.0, 68.0, 68.0, 68.0, 68.0, 68.0 68.0, 68.0, 68.0, 68.0, 68.0, 68.0, 68.0, 68.0
Cooling Thermostat Settings	78.0, 78.0, 78.0, 78.0, 78.0, 78.0, 78.0, 78.0 78.0, 78.0, 78.0, 78.0, 78.0, 78.0, 78.0, 78.0 78.0, 78.0, 78.0, 78.0, 78.0, 78.0, 78.0, 78.0