

Annual Energy Summary

Wholehouse Summary

FSEC
111 Anywhere Lane
Colorado Springs, CO

Project Title: TMY_City:CO_COLORADOSPRINGS
DSE_HVAC-3d
Building Type: User
HERS BESTEST basement case

Elec Util: EnergyGauge Default
Gas Util: Florida 2012
2/16/2018

End-Use	Energy Consumption	Annual Cost
Cooling		
Cooling Fan	0 kWh	\$0
Mechanical Vent Fan	0 kWh	\$0
Total Cooling	0 kWh	\$0
Heating		
Therms	869.5 Therms	\$1478
Heating Fan/Pump	623 kWh	\$74
Mechanical Vent Fan	0 kWh	\$0
Total Heating		\$1552
Hot Water	0 kWh	\$0
Hot Water Pump	0 kWh	\$0
Total Hot Water	0 kWh	\$0
Ceiling Fans	0 kWh	\$0
Clothes Washer	37 kWh	\$4
Dehumidifier	0 kWh	\$0
Dishwasher	78 kWh	\$9
Dryer Electric	372 kWh	\$44
Lighting	1863 kWh	\$221
Miscellaneous	1401 kWh	\$166
Pool Pump	0 kWh	\$0
Range Electric	331 kWh	\$39
Refrigerator	637 kWh	\$76
Television	413 kWh	\$49
Total (kWh)	5754 kWh	\$684
Total (Therms)	869.5 Therms	\$1478
Total (Oil Gallons)	0 Gallons	\$0
Total (Propane Gallons)	0 Gallons	\$0
PV Produced (kWh)	0 kWh	\$0
Assumes net metering		
Total Cost		\$2162

Emissions (Calculated as Total - PV Produced)
SO2 = 10.96 Lbs NOX = 8100.92 Lbs CO2 = 10.11 Tons