

Annual Energy Summary

Wholehouse Summary

FSEC
111 Anywhere Lane
Colorado Springs, CO

Project Title:
HVAC_TestCase-2c
Building Type: User
HERS BESTEST basecase home

TMY_City:CO_COLORADOSPRINGS
Elec Util: EnergyGauge Default
Gas Util: Florida 2012
2/16/2018

End-Use	Energy Consumption	Annual Cost
Cooling		
Cooling Fan	0 kWh	\$0
Mechanical Vent Fan	0 kWh	\$0
Total Cooling	0 kWh	\$0
Heating Electric	9996 kWh	\$1188
Heating Fan/Pump	1407 kWh	\$167
Mechanical Vent Fan	0 kWh	\$0
Total Heating	11403 kWh	\$1355
Hot Water	0 kWh	\$0
Hot Water Pump	0 kWh	\$0
Total Hot Water	0 kWh	\$0
Ceiling Fans	0 kWh	\$0
Clothes Washer	37 kWh	\$4
Dehumidifier	0 kWh	\$0
Dishwasher	78 kWh	\$9
Dryer Electric	372 kWh	\$44
Lighting	1863 kWh	\$221
Miscellaneous	1401 kWh	\$166
Pool Pump	0 kWh	\$0
Range Electric	331 kWh	\$39
Refrigerator	637 kWh	\$76
Television	413 kWh	\$49
Total (kWh)	16534 kWh	\$1964
Total (Therms)	0.0 Therms	\$0
Total (Oil Gallons)	0 Gallons	\$0
Total (Propane Gallons)	0 Gallons	\$0
PV Produced (kWh)	0 kWh	\$0
Assumes net metering		
Total Cost		\$1964

Emissions (Calculated as Total - PV Produced)

SO2 = 31.48 Lbs NOX = 41.86 Lbs CO2 = 14.36 Tons